

# JUBILEE HILLS PUBLIC SCHOOL

ISO Certified: 9001: 2015



Ref: JHPS/Admin/178/2023-24

Date: 22.08.2023

To The Director General, Fire Prevention Wing, Hyderabad.

Dear Sir,

Sub: Submission of self-certification form in the prescribed proforma - Reg.

Ref: 1)Renewal Fire NOC issued vide R.C.No: AD/FPW/GHMC/2015 Dated 14-09-2015

2)Circular Memorandum Rc No.4039-2/EODB/2015 dated 05-03-2016

3) G.O.Ms No: 56 dated 26-07-2019

4) Acknowledgement of Self certification dated 11-10-2019

We are here with submitting the self-certification form in Annexure-1 for the period 23-08-2023 to 22-08-2028 along with the following supporting documents for your perusal.

- 1. Fire No Objection Certificate issued by Commissioner, GHMC Dated 14.9.2015.
- 2. Acknowledgement of Self certification dated 11-10-2019
- 3. Copy of G.O Ms. No.56 dated 26<sup>th</sup> July 2019- Para 7 i.e., buildings after 13-04-2009
- 4. Circular Memorandum Rc No.4039-2/EODB/2015 dated 05-03-2016

Please do the needful at the earliest.

Thanking You,

For JUBILEE HILLS PUBLIC SCHOOL

**PRINCIPAL** 

Encl: As above.

H. Varalaker

anchaver Va JUBILEE HILLS PUBLIC SCHOOL Block No.3, Road No.71 Jubilee Hills, Hyderabad-500 096.

For Jubilee Hills Public School, Hyderabad

M. Varalokhui

Road No. 71, Jubilee Hills, Hyderabad, Telangana - 500 033.

Phones: 23548584, 23607797

Email: info@jhpublicschool.com Webstie: www.jhpublicschool.com

Annewar 3

#### ELATER HYDERABAD MUNCHALL CONFORCION FIRE PREVENTION & CO.

From:

The Commissioner.

Greater Hydecabad Municipal Corporation, Hyderabad (a.

Distract ladicational Officer,

Hyderabad District.

Sir,

Sub:- Greater Hyderabad Municipal Corporation - Existing Non - Multi Storied Building of Jubilee Hills Public School, represented by Jubilee Hills Education Society, (Occupied & Underuse). Situated at D.No: 8-2-293/1/11, Road No: 71, Jubilee Hills, Hyderabad - Issuance of RENEWAL OF FIRE NO OBJECTION CERTIFICATE. Regarding

- Ref. 1. Proceeding Ro. No; 5041/B2/97, Dated: 12-03-2010 of the Director General of State Disaster Response and Fire Services Department, Andhra Pradesh, Hyderabad.
  - Fire NOC Issued Vide RC.No:1467/AD/FPW/GHMC/2011, Dated:19-12-2011 by the Commissioner, GHMC, Hyderabad.
  - Renewal of Fire NOC Issued Vide RC.No:331/AD/FPW/GHM@/2014, Dated:23-09-2014 by the Commissioner, OHMC, Hyderabad.
  - Application Dated; 30.07.2015 of The Correspondent C/o. Jubilee Hills Public School, represented by Jubilee Hills Education Society, Road No. 71, Jubilea Hills, Hyderabad.

Under the Powers delegated vide reference 1st Cited the District Birs Officer along with Station Fire Officer, Central Zone have inspected the Existing Non - Milly Storied Building occupied by Jubilee Hills Public School, represented by Jubilee Hills Education Society, Situated at D.No: 8-2-293/1/11, Road No. 71, Jubilee Hills, Hyderabad on 13:08:2015 and submit the following report.

2) The Non-Multi Storied Existing building (Occupied & Underuso) consists of Cellar +
Still + Ground + Two Floors with a height of 14.45 Mirs for Educational Occupancy (School)
and was issued Fire No Objection Certificate Vide reference 3rd Cited. Vide reference 4th Cited,
the management has requested for RENEWAL OF FIRE NO OBJECTION CERTIFICATE
due to completion of One Year.

3)	PARTICULARS OF	THE BUILDING:
1	Address of the building	JUBILEE HILLS PUBLIC SCHOOL, REPRESENTED BY JUBILEE HILLS EDUCATION SOCIETY, DINO: 8-2-293/1/11, ROAD NO: 71, JUBILEE HILLS, HYDERABAD.
10)	Built-up area/Height	3092.47 Sq. Mtrs/ 14,45 Mtis
(0)	No of blocks / floors	One/Cellar + Still + Ground + Two Floors
di	Type of occupancy	Educational Building (B)

::1::

Ranchana Valli

ILEE HILLS PUBLIC SCHOOL

PIONINES HILLS MUSIC SCHOOL

H Jaralokelmi

Ang freq

M. Varala Kahuni

For Jubile Hills Public School, Hyderabad

of the Dog the Director

Arabang's accumable

For Jubilee Hills Public School

M. VARALAKSHMI "

y Vacalof For JUBILEE HILLS PUBLIC SCHOOL

il.	OOR WISE DELAILS	Area in Sq. Meters:	Occupancy	Occupant Load
0	CELLAR FLOOR	520.13	Parking	Parking
-	STILT FLOOR	643.09	Games & Sports	Games & Sports
4	GROUND FLOOR	643.09	Educational	200
,	FIRST FLOOR	643.09	Educational	150
}	SECOND FLOOR	643.09	. Educational	150
5	SECOND FLOOR	2007.47		, , , ,

The builder has provided Two Internal statecases with a width of 02.50 & 01.50 meters. One External Staircase with a width of 01.50 meters. The occupant Load as per area is 643.09/4 = 160.77 Nos, and exit width required as per the Occupant load given by the management is 150/25 = 06.00 units of 0.50 meters i.e. 03:00 meters & aggregate exit width provided is 05.50 meters.

OPEN SPACES Directions	ALL ROUND BUILDING:  Open space to be provided  as per the G.Q. M3. No. 163,  MAUD(M) Department,  Dated: 07-04-2012 inder	Open spaces provided by the builder.	Delicit
	Section -7/1 in Table -111	03:00 Mtrs	NII (Road)
NORTH (Front)	06.00 11/5	06,00 Mirs	Till
WEST	06.00 Miss.	06.00 Mus 07.30 Mtrs	NI
SOUTH	06.00 Mirs.	07.30 14103	

6) The Minimum Fire Safety Installations required & provided by the builder as per the Table 23 of Part-4 of N.B.C of India 2005. 11 11 15 11/25

i rm	144 Of M.D.C Of Middle 2000	historia I	Provided	Deficit
SL	Fire Safety Measures	Required	7,0,100	12
No	<u>Vicar 5 A</u>	Required	Provided	Mil
1.	Fire Extinguishers as per 18:2190	Required	01 No. in each Floor	Nil
2,	Hose Reel	Required	01 No.	Nil
3.	Down Comer	Not		Nil.
4.	Landing Valve + Hose Box + (02) Nos. Delivery Hose	Required	01 No. in each Floor	
.5.	Automatic Sprinkler System in Cellars	Required	Provided	1/01
6.	Manually Operated Electrical Rice +1	Not Required	01 No. in each Floor	Nil
	Atam System 3 5 6 75  Terrace Tank of 10,000 Ltm 19a 345	Required	22,000 Lins(Sintex)	Nil
7.	Terrace Lank of 10.000 fals years	Required	Provided	Nil
8.	Booster Pump of 450 LPM Four Way Fire Brigade Infet	Required	Provided	Nil

::2::

or JUBILEE HILLS PUBLIC SCHOOL PROCESSION

And olas

PRINCIPAL

7) In View of the above, RENEWAL OF FIRE NO OBJECTION CERTIFICATE for the above said building is issued subject to the following Conditions

- The NOC issued is confined to the Fire Safety measures installed in the building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use / Occupancy or Building Regularization. The Owner / Occupier shall comply the Building Rules /Govt Orders as applicable
- Fixed and first-aid Fire Fighting equipment, alarm ets shall be tested and maintained regularly as per applicable standards and Fire-Drills conducted quarterly for first two years and half yearly after two Years.
- No temporary structure such as tents or with thatched construction should be allowed for educational institutions.
- Emergency power generator etc., and associated equipment should be fested periodically, verified as per NBC, and IS-1646.
- The Management is to provide 10,000 Lirs Water Tank with RCC Construction at the terrace level within 93 months (or) Otherwise connect to Terrace Tank already available.
- Every room with a capacity of 45 students shall be maintained obstruction free minimum two doorways.
- Every vertical opening between at the floors shall be suitably enclosed or protected, with 7, ventilation System by ducts and Balconies.
- The Builder / Occupier should facilitate periodical Inspection by jurisdiction Station Fire Officer and District Fire Officer, Fire Prevention Wing, GHMC, Hyderabad.
- Evacuation plan at showing exit routes and recommended action plan be displayed at conspicuous locations and shall be exhibited all times, all escape lexit routes shall not be blocked or encroached.
- 10. Fresh NOC would be required for any change in occupancy or additions/alterations in the building structure as per NBC of India and building byellaws.
- 11. The Management has to maintain Fire Safety Measures at all times in good working Condition as seen during the inspection.
- 12. Any Loss of life or property due to Non functioning of Fire Safety Measures and other installations shall be the responsibility of the management/owner.
- 13. All the Occupants must know the correct method of operation of the Fire Fighting System installed.

Kanchema Valli Por manus mus evalue achoo.

Author's avantory

::3::

For Jubile Public School, Hyderabad

For Jubilee Hills Public School

H. Vacalofelini

M. VARALAKSHIM

For JUBILEE HILLS PUBLIC SCHOOL

- 14. All Occupants/ security personnel shall be trained to operate the time Sarety Equipment during the Emergency
- 15. Additional/Alteration, if any, in the building may be verified by building authority.
- 16. The Fire Drills Shall be conducted once in every Six months for initial two years, thereafter, once in every 3 months,
- 17. This RENEWAL OF FIRE NO OBJECTION CERTIFICATE is valid for one year from the date of issue, it is the responsibility of the builder I Occupier to apply for renewal of Fire NOC, two months before expiry of this Fire NOC.

COMMISSIONER GHMC, HYDERABAD

#### Copy to:

- 1) The Correspondent Clo. Jubiles Hills Public School, represented by Jubilee Hills Education Society, Road No. 71, Jubilee Hills, Hyderabad.
- 2) The Chief City Planner, GHMC, Hyderabad.

For JUBILER HILLS PUBLIC SCHOOL

For Jubilee Hills Public School, Hyderabad M. Varalakohumi

Director

Kanchana Valli Block No.3, Road No.71 Jubilee Hills, Hyderabad-500 096.

> Signature Digitally signed by S.DEVENDAR REDAY Date: 201009. 35-26 IST Date: 2017 0

1:4::

has yneited hitte anbric echool.

For JUBILEE HILLS PUBLIC SCHOOL

And Hot of

For Jubilee Hills Public School

PRINCIPAL

### ANNEXURE

(Annexure to G.O.Ms No. 56, Home (Ser.IV) Department, Date: 26-07-2019) Justructions to be followed for Schools Existing before 13-04-2009

<u>Self Certification of Fire Safety Measures by School Management:</u>

General Information for School Buildings of all categories i.e. A, B, C, & D.

SL.NO.	DETAILS	angs of all categories i.e. A, B, C, &
1.	Date of the Opening of the School building	
2.	Name of the Applicant	02/12/2009
3.	Name and Address of the School	Jubilee Hills Public School
	- The section of the section	D No: 8-2-293/1/11.Rd No 71
4.	Telephone Number and E-Mail	Jubilee Hills, Hyderabad - 5000c
	A TANADOL CINC E-MAII	040-23548584.
5.	Height of the building (in meters)	info@jhpublicschool.com
6.	No. of floors	14.45 mts
7.	Abutting Road width (in meters)	G+2
8.	Built - up area of each floor in Sq.mts	50'_0" and wide road
	Stilt	Cellar : 520.13
	Ground	Stilt: 643.09
	Floor 1	Ground :643,09
	Floor 2	First: 643.09
	Floor 3	Second: 643.09
	Number of State cases	
	Stair case 1	
	Stall Case Z + (width in motors)	2.5 mts
	Totali Lase 3 (Width in material	1.5 mts
0.	Width of each Stair case	1.5 mts
1,	Open spaces	Aggregate 5.5 mts
	Bront	The control of the co
	Side I (width in makeus)	North: 3.00mts
	Old A washing wildfill in motomi	East: 6.00mts
,	Rear (width in meters)	West: 6.00mts
		South: 7.30 mts

Ang trust P.

(Signature with date of School Authority and Seal)

Ranchema Valli JUBILEE HILLS PUBLIC SCHOOL Block No.3, Road No.71 Jubilee Hills, Hyderabad-500 096.

For Jubilee Hills Public School, Hyderabad

Director



For Jubilee Hills Public School H. Varalakshiri

TOT JUBILEE HILLS PUBLIC SCHOOL

») SCHOOL BUBLINGS WITH GROUND PLUS TWO GLOOKS AND LESS THAN THE METERS IN (HEIGHT):

SLNo.	Fire Equipment	Scale of Fire Equipment as per	Required	Provided
	Required	Norms		Yes/No
1.	Fire Extinguishers (IS 2190:2010)	Two 09 litres water expelling Extinguishers or ABC 4kgs Fire Extension, for every 200 square meters with minimum of 04 nos Extinguishers per Compartment/floor. The Extinguisher Should be so located as to be available with in 15meter radius	Required	Yes
2.	First Aid Hose Reel (IS 884:1985)	1No's for every 1000 square meter	Required	1nos in each floor
3.	Terrace Tank over respective Tower Terrace	10,000 litres (5,000 litres additionally shall be provided if basement exceeds 200 square meters)	Required	22,000 lts
4.	Automatic Sprinkler System (IS 15105 :2002) The IS Standard may be downloaded from http://www.bis.gov.in	To be installed in basement. If area of basement exceeds 200 sq mts.	Required	Provided .
5.	Pump capacity LPM at the terrace tank level with minimum 3.5 kg/cm <sup>2</sup>	450 LPM (450 LPM additionally shall be Provided if basement exceeds 200 square meters)	Required	Provided
	Additional Fire Safe	ety Measure in lieu of deficiency in se	t backs	
1.	Water Shower Curtain	Water Shower curtain shall be provided in all floors on the side/sides having deficiency of setback to overcome exposure hazard from fires from neighboring property	Not Required	
Viz. Committee	Fire Brigade Inlet	02 no's	Required	Provide

Note: If the floor area in a single floor is more than 500 square meters and there is only one single stair case, a second stair case of 1.5 meter width shall be provided with concrete (or) metal structure.

> A-19 19492 (Signature with date of School authority and Seal

Kanchana Valli JUBILEE HILLS PUBLIC SCHOOL Block No.3, Road No.71 Jubilee Hills, Hyderabad-500 096.

For Jubilee Hills Public School, Hyderabad

M. Varalakshini

Director

And Home TLEE HILLS PUBLIC SCHOOL

For Jubilee Hills Public School

M. Varalakthuri M. VARALAKSHIVII PRINCIPAL

. Nate

aGeneral Fire Safety Measures which should be followed by all schools.

		YES/NO
1.	The School building shall not be housed in temporary structures with roofs of tent cloth, thatched or any other combustible materials	Yes
2.	It should be ensured that the available Fire Safety Equipment is always in good working condition	Yes
3.	Pre-school, Kinder Garden and Class/Grade-1 students shall be located on ground floor/level of Exit discharge and Class/Grade-2 students shall be located not above one Floor higher than ground floor/level of Exit discharge	Yes
4.	Kitchen should be constructed/provided away from the school building	Yes
5,	All schools shall prepare and Evacuation plan in consultation with Local Fire Officer	Yes
6.	All Teachers/Employees should be trained in operating the available Fire Safety Equipment in the building.	Yes
<b>7.</b>	All Exits/Escape routes shall be kept free from any obstructions for free passage in case of any emergency	Yes
8.	All the Internal stair cases, lifts, lobbies and corridors should be adequately ventilated and illuminated	Yes
9.	If the school is provided with Central Air conditioning system, all safety measures as per Clause 10.1 is IS 14435:1997 should be followed	No Central Air Conditioning system
10	School Buildings shall be kept free from inflammable and toxic materials. If storage is inevitable, they should be store safely.	Yes
11.	Any Hazardous/Combustible Material/Volatile Flammable liquids shall be stored in School Buildings	Yes
12.	DOs and DONTs in case of Emergency shall be displayed at Strategic Locations of the building	Yes
13.	Auto Glow Sign Boards Shall be provided indicating Exists/Escape Routes	Yes
4	Blectrical wiring in the Entire building shall be checked and certified by the competent authority.	Yes
5	Structural Stability of the building shall be checked and certified by the competent authority	Yes
6	Public Address System shall be provided for the use in case of any emergency and this system shall cover the entire building	Yes
7	Detailed information regarding the number of Students in each Class room and the number of teachers/employees working shall be displayed at Strategic Locations of the buildings	Yes
8'	Display all Emergency Supporting Numbers such as Nearest Fire Stations, Police Station, Hospitals/Ambulance etc. On all floors and Strategic Locations	Yes
9	A pictorial map with details of Entry/Exits, details of Class Rooms, Labs, Staff Rooms and open place (Assembly Point) of the school buildings shall be prepared and displayed in Strategic Locations.	Yes
)	If Basement area of the building exceeds 200 square meters, required to provide Automatic Sprinkler system as per IS	Yes

Jubilee Hills Public School

PRINCIPAL

PRINCIPAL

JUBILEE HILLS PUBLIC SCHOOL

Block No.3, Road MARYLAKSHMI

Jubilee Hills, Hyderabad-500 096.

For Jubilee Hills Public School, Hyderabad

M. Varabakehills

Chairman

**Director** 

We Jubilee Hills Public is hool Management/Correspondent hereby declare and certify that the information furnished is correct and if it is noticed at any time that the information provided is False, we understand that our School affiliation may be cancelled by the Concerned Authority. We have installed fire safety measures as per Annexure I and undertake to maintain the same in good working condition at all times

> Ang Hongamel. (Signature with date of School authority and Seal



Kanchauer Valli

PRINCIPAL JUBILEE HILLS PUBLIC SCHOOL Block No.3, Road No.71 Jubilee Hills, Hyderabad-500 096. For Jubilee Hills Public School, Hyderabad H. Vacalakhun

Director

For Jubilee Hills Public School

M. Varalakehni

M. VARALAKSHMI PRINCIPAL

- MBILEE HILLS PUBLIC SCHOOL



## JUBILEE HILLS PUBLIC SCHOOL

CBSE AFFILIATION NO. 3630020



JHPS/CBSE/142/2023-24

Date: 06.07.2023

To

Central Board of Secondary Education

**Affiliation Department** 

New Delhi

#### Subject: Fire Safety Certificate

With regard to the Fire Safety Certificate we are herewith enclosing G.O.M.S.No.56 dated 26.07.2019 (copy enclosed) issued by Government of Telangana where in point No.6 it states that for school buildings existing before 2009 as per Supreme Court order dated 13.04.2009, shall follow the Fire Safety norms as recommended by expert committee as detailed in the Annexure I appended to this order for the purpose of obtaining recognition/ affiliation with self-certification forms. The officers of Fire Department will conduct surprise inspection randomly and if any deviation from self-certification forms are noticed, the same will be intimated to the concerned authority of education department recommending for cancellation of the affiliation / recognition.

Hence we can only submit self-certification certificate as Annexure I and the G.O.No.56 with regard to Fire Safety Certificate.

We request you to consider the same and do the needful.

Thanking you,

For Jubilee Hills Public School

M. Varalakshmi

PRINCIPAL

Encl: 1, G.O.M.S.No.56 dt.26.07.2019

nci. 1. G.O.M.S.No.30 dt.20.07.2019

2. Self-certification in Annexure I

JUBILEE HILLS PUBLIC SCHOOL

Block No.3, Road No.71 Jubilee Hills, Hyderabad-500 096. For Jubilee Hills Public School, Hyderabad

Directo

#### GOVERNMENT OF TELANGANA ABSTRACT

Home Department - Fire Services - Directions of Hon'ble Supreme Court of India dated:13.04.2009 in W.P. No.483 of 2004 - Fire Safety measures to be followed in the Schools - Orders - Issued.

#### HOME (SERVICES.IV) DEPARTMENT

#### G.O.Ms.No.56,

Dated: 26,07,2019, Read the Following:-

Telangana Fire Service Act, 1999.

2. National Building Code of India, 2016.

3. Hon'ble Supreme Court of India Judgment dated: 13.04.2009 in W.P. No.483 of 2004.

4. From the Director General of State Disaster Response and Fire Services, Telangana, Hyderabad Letter Rc.No. 8109/MSB/2016, dated:28.02.2018.

5. G.O.Rt.No.442 Home (Services.IV) Department, dated:28.03.2018.

6. From the Director General of State Disaster Response and Fire Services, Telangana, Hyderabad Letter Rc.No. 8109/MSB/2016, dated:29.05.2018.

7. From School Education (General) Department U.O.Note No.4590/SE.Genl/A2/2018-3, dated:14.08.2018.

8. From the Director General of State Disaster Response and Fire Services, Telangana, Hyderabad Lr.Rc.No.8109/MSB/2019, dated.22.06.2019.

(\*\*\*\*\*)

#### ORDER:

Hon'ble Supreme Court of India in its Judgment dated: 13.04.2009 in W.P. No.483 of 2004 have issued the following directions keeping in view of the Safety and Security of School going children which has utmost importance:

"It has become imperative to direct that, Safety Measures as prescribed by the National Building Code of India, 2005 be implemented by all Government and Private Schools functioning in our Country.

- (i) Before Granting recognition or affiliation, the concerned State Government and Union Territories are directed to ensure that the buildings are safe and secure from every angle and they are constructed according to the safety norms incorporated in the National Building Code of India.
- (ii) All Existing Government and Private Schools shall install fire extinguishing equipment within a period of Six Months.
- (iii) The School Buildings be kept free from inflammable and toxic material. If storage is inevitable, they should be stored safely.
- (iv) Evaluation of structure aspect of the school may be carried out periodically. We direct that the concerned engineers and officials must strictly follow the National Building Code. The Safety Certificate be Issued only after proper inspection. Dereliction in duty must attract immediate disciplinary action against the concerned officials.
- (v) Necessary training be imparted to the staff and other officials of the school to use the Fire extinguishing equipment".
- The Director General of State Disaster Response & Fire Services, Telangana, Hyderabad in his letter 4th read above has requested the Government to constitute an Expert Committee on Setbacks and Retrofitting of Fire Safety installations in the

Contd/-2 For Jubilee Hills Public School, Hyderabad Scanned by Camscan

Director

Canchana Valli JUBILEE HILLS PUBLIC SCHOOL Block No.3, Road No.71 Jubilee Hills, Hyderabad-500 096. existing school buildings as per the directions of the Hon'ble Supreme Court, Accordingly, Government have constituted the Expert Committee with the following Members to suggest norms for different Educational institutions existing prior to the order of the Hon'ble Supreme Court Judgment and also to suggest standard norms applicable for such institutions regarding setbacks and retrofitting of the Fire Safety Installations in the existing School buildings vide G.O. 5" read above:

•	Director General, Telangana State Disaster Response & Fire Services Hyderabad	Chairman
li	One expert from Telangana State Disaster Response & Fire Services Hyderabad	Member
III	One expert from the Town & Country Planning Department, MA&UD Department	Member
iv	Senior representative from Education Department	Member
V	Representative of School Management Association	Member

- The Expert Committee has submitted its report with specific recommendations the Director General, TSDR & FS has submitted the recommendations to the Government vide letter 6th read above.
- Subsequently, the Chief Secretary to Government has convened a meeting with all the concerned on 12.06.2019 on the fire safety issues in schools and decided to issue guidelines on the issues of Fire Safety in the Schools. The Director General, Telangana State Disaster Response & Fire Services Department has also furnished his remarks to Government vide letter 8th read above.
- Government after careful consideration of the decisions taken in the meeting convened by the Chief Secretary to Government on 12.06.2019 and also further remarks of the Director General, Telangana State Disaster Response & Fire Services Department and in compliance of the directions of the Hon'ble Supreme Court of India in its Judgement dated:13.04.2009 in W.P. No.483 of 2004, here by order that, all Schools existing before the Hon'ble Supreme Court Order I.e., dated:13.04.2009, shall follow the Fire Safety norms as recommended by the Expert Committee as detailed in the Annexure-I appended to this order, for the purpose of obtaining the affiliation/recognition. Further Self Certification forms shall be submitted by the Schools for the purpose of affiliation/recognition to the Authority concerned of Education Department, in the proforma prescribed at Annexure-I appended, duly marking a copy to the jurisdictional Divisional Fire Officer, The Officers of Telangana State Disaster Response & Fire Service will conduct surprise inspections randomly and if any deviations from Self Certification forms are noticed, the same will be intimated to the concerned authority of Department recommending for the cancellation Education affiliation/recognition.
- Further, all Schools constructed after the Hon'ble Supreme Court Order dated:13.04.2009 shall follow the Safety norms of National Building Code of India. The Telangana State Disaster Response & Fire Services Department will Issue Fire No Objection Certificate (NOC) for those schools which come within the purview of Section 13 (1) of Telangana Fire Service Act 1999, that is, Schools which more than 500 Sq.Mtrs in Plot area or 6 Mtrs and above in height duly following the norms of National Building Code of India.
- All other schools constructed after the Hon'ble Supreme Court order dated:13.04.2009 and which do not come within the purview of the Telangana Fire Service Act, 1999 shall submit self certification forms in the proforma prescribed at Annexure-II appended to this order, to the concerned Authority of the Education Department for the purpose of affiliation/recognition by the Education Department duly marking a copy to the jurisdictional Divisional Fire Officer. The Officers of Ranchome Vallangana State Disaster Response & Fire Service will conduct surprise inspections

PRINCIPAL JUBILEE HILLS PUBLIC SCHOOL Block No.3, Road No.71 Jubilee Hills, Hyderabad-500 096. For Jubilee Hills Public School, Hyderabad Scanned by CamScanner H. Varalakhun

randomly and if any deviations from self certification forms are noticed, the same will be intimated to the concerned authority of Education Department recommending for the cancellation of the affiliation / recognition.

9, All the Departments concerned shall take necessary action accordingly in the matter.

### (BY ORDER AND IN THE NAME OF THE GOVERNOR OF TELANGANA)

#### RAJIV TRIVEDI PRINCIPAL SECRETARY TO GOVERNMENT

To

The Secretary, School Education Department.

The Director General, Telangana State Disaster Response

& Fire Service Department.

The Director, School Education Department, Telangana State, Hyderabad.

Copy to:

All the Regional Joint Directors of School Education through Director of School Education Department.

All the District Educational Officers in the State through the Director of School Education Department,

P.S. to Minister for Home.

P.S. to Minister for Education.

P.S. to Chief Secretary to Government.

P.S. to Principal Secretary to Govt., Home Department.

P.S. to Secretary to Govt., School Education Department. SF/Sc.

// FORWARDED :: BY ORDER//

Ranchaua Valli JUBILEE HILLS PUBLIC SCHOOL Block No.3, Road No.71 Jubilee Hills, Hyderabad-500 096.

For Jubilee Hills Public School, Hyderabad

M. Varalakshimi

Director