

GREATER HYDERABAD MUNICIPAL CORPORATION



NO: 09/HS/C.18/GHMC/2025-26.

Date: 01-03-2025.

SANITARY CERTIFICATE
FOR SANITARY PURPOSE OF THE 2025-2026

This is to certify that **M/S. JUBILEE HILLS PUBLIC SCHOOL, Premises No. ROAD NO.71, Jubilee Hills, Hyderabad, GHMC, Telangana.** Is having sufficient accommodation for all the classes for the existing number of students taught in their school and properly ventilated it is found that the building is maintained in good condition with respect to sanitation drinking water is made available in clean receptacles having a lid on the top and tap at the bottom and are kept at safe place with coolers and aqua-guard water filters. The management shall maintain existing latrines and urinals separately for boys and girls and also the staff neat and clean at all the time.

The Sanitary Certificate is only for sanitation purpose only. It does not confer any power or permission for the schools temporary or permanent exemption from the provisions of any other section of HMC Act, Bye-laws or rules in force.

Period of Validity: This certificate is valid for the financial year 2025-26.

[Signature]
Asst. Medical Officer Health
Circle No. 18, GHMC
Asst Medical Officer of Health
Circle No: 18, GHMC

To,
M/S. JUBILEE HILLS PUBLIC SCHOOL,
Premises No. ROAD NO.71, Jubilee Hills,
Hyderabad, GHMC, Telangana.

Kanchana Valli
PRINCIPAL
JUBILEE HILLS PUBLIC SCHOOL
Block No.3, Road No.71
Jubilee Hills, Hyderabad-500 096.

For Jubilee Hills Public School, Hyderabad

H. Varalakshmi
Director

TEST REPORT



ULR : TC591825400003067F

Issued to:

Acer Engineers (P) Ltd.,
Sy. No. 17/AA, Manjeera Dam Road
Chintalapally (V) - 502 294
Sangareddy (M), Sangareddy District
Kind Attn.: Mr. P. Srinivasa Rao, 98496-96001

Report No. : LL/25-26/002943

Issue Date : 25/06/2025

Customer Ref.: Letter

Ref. Date : 06/06/2025

Sample Particulars : PACKAGED DRINKING WATER

Brand Name : Bibo	Best Before Use : 6 Months From DOM
Qty. Received : 1 Ltr X 4nos, Pet bottles, Ambient condition	
Batch No.: 0506AS	
Date of Manufacture : 05/06/2025	
Test Parameters : Faecal Streptococci, Staphylococcus aureus, Salmonella, Shigella, Vibrio cholerae, Vibrio parahaemolyticus, Phenolic compounds, Mineral oil, Antimony, Borate, Anionic surface active agents, Zinc, Barium, Copper, Iron, Manganese	
Date of Receipt of Sample : 14/06/2025	Date of Starting of Analysis : 14/06/2025
Date of completion of analysis : 25/06/2025	SAMPLE TESTED AS RECEIVED

TEST RESULTS

Clause No.	Parameters	Units	Test Method	Specification, 14543:2024	Results
Microbiological Tests					
	DISCIPLINE: Biological testing				
	GROUP: Water				
CLAUSE: 5.2					
5.2.3	Faecal Streptococci	Per 250mL	IS 15186 : 2002	Shall be Absent	Absent
5.2.3	Staphylococcus aureus	Per 250mL	IS 5887 Part 2 : 1976	Shall be Absent	Absent
5.2.8	Salmonella	Per 250mL	IS 15187 : 2016	Shall be Absent	Absent
5.2.8	Shigella	Per 250mL	IS 5887 Part 7 : 1999	Shall be Absent	Absent
5.2.9	Vibrio cholerae	Per 250mL	IS 5887 Part 5/Sec1 : 2023	Shall be Absent	Absent
5.2.9	Vibrio parahaemolyticus	Per 250mL	IS 5887 Part 5/Sec1 : 2023	Shall be Absent	Absent

Kanchana Valli
PRINCIPAL
JUBILEE HILLS PUBLIC SCHOOL
Block No.3, Road No.71
Jubilee Hills, Hyderabad-500 096.

For Jubilee Hills Public School, Hyderabad

H. Varalakshmi
Director

L. Sandhya
Reviewed by

L. Sandhya
L. Sandhya
Authorized Signatory

TEST REPORT



ULR : TC591825400003067F

Issued to:

Acer Engineers (P) Ltd.,
Sy. No. 17/AA, Manjeera Dam Road
Chintalapally (V) - 502 294
Sangareddy (M), Sangareddy District
Kind Attn.: Mr. P Srinivasa Rao, 98496-96001

Report No. : LL/25-26/002943

Issue Date : 25/06/2025

Customer Ref.: Letter

Ref. Date : 06/06/2025

Sample Particulars : PACKAGED DRINKING WATER

Brand Name : Bibo
Qty. Received : 1 Ltr X 4nos, Pet bottles, Ambient condition
Batch No.: 0506AS
Date of Manufacture : 05/06/2025
Best Before Use : 6 Months From DOM
Test Parameters : Faecal Streptococci, Staphylococcus aureus, Salmonella, Shigella, Vibrio cholerae, Vibrio parahaemolyticus, Phenolic compounds, Mineral oil, Antimony, Borate, Anionic surface active agents, Zinc, Barium, Copper, Iron, Manganese
Date of Receipt of Sample : 14/06/2025
Date of Starting of Analysis : 14/06/2025
Date of completion of analysis : 25/06/2025
SAMPLE TESTED AS RECEIVED

TEST RESULTS

Clause No.	Parameters	Units	Test Method	Specification, 14543:2024	Results
Chemical Tests					
	DISCIPLINE: Chemical testing				
	GROUP: Water				
CLAUSE: 5.3					
(xix)	Phenolic compounds (as C ₆ H ₅ OH)	mg/L	IS 3025 Part 43 : 2021	0.001 Max	<0.001
(xx)	Mineral oil	mg/L	IS 3025 Part 39 : 2021	1.0 Max	<1.0
(xxiii)	Antimony (as Sb)	mg/L	IS 3025 Part 2 : 2019	0.005 Max	<0.005
(xxiv)	Borate (as B)	mg/L	IS 3025 Part 2 : 2019	5.0 Max	0.05
(vii)	Zinc (as Zn)	mg/L	IS 3025 Part 2 : 2019	5.0 Max	<0.02
(xxi)	Anionic surface active agents (as MBAS)	mg/L	IS 3025 Part 68 : 2019	0.2 Max	<0.1
(i)	Barium (as Ba)	mg/L	IS 3025 Part 2 : 2019	0.7 Max	0.01
(ii)	Copper (as Cu)	mg/L	IS 3025 Part 2 : 2019	0.05 Max	<0.02
(iii)	Iron (as Fe)	mg/L	IS 3025 Part 2 : 2019	0.1 Max	<0.02
(iv)	Manganese (as Mn)	mg/L	IS 3025 Part 2 : 2019	0.1 Max	<0.02

NOTE : This report and results relate only to the sample / items tested.

End of Report

Kanchana Valli
PRINCIPAL
JUBILEE HILLS PUBLIC SCHOOL
Block No.3, Road No.71
Jubilee Hills, Hyderabad-500 096.

For Jubilee Hills Public School, Hyderabad

H. Varalakshmi
Director

S. Satyanarayana
Reviewed by

S. Satyanarayana
Authorized Signatory